

# Engineering Schedule for Berner's SRC Unit

## Energy Recovery Unit Schedule

| Unit ID | Manufacture | Model # | Supply Air Flow |                |           | Exhaust Air Flow |                |           | Base Eff. | Summer Conditions |    |            |    | Winter Conditions |     |            |     |  |
|---------|-------------|---------|-----------------|----------------|-----------|------------------|----------------|-----------|-----------|-------------------|----|------------|----|-------------------|-----|------------|-----|--|
|         |             |         | CFM             | E.S.P<br>in wc | Fan<br>HP | CFM              | E.S.P<br>in wc | Fan<br>HP |           | Outside Air       |    | Return Air |    | Outside Air       |     | Return Air |     |  |
|         |             |         |                 |                |           |                  |                |           |           | db                | wb | db         | wb | db                | %RH | db         | %RH |  |
| ERU-1   | Berner      |         |                 |                |           |                  |                |           |           |                   |    |            |    |                   |     |            |     |  |
| ERU-2   | Berner      |         |                 |                |           |                  |                |           |           |                   |    |            |    |                   |     |            |     |  |
| ERU-3   | Berner      |         |                 |                |           |                  |                |           |           |                   |    |            |    |                   |     |            |     |  |
| ERU-4   | Berner      |         |                 |                |           |                  |                |           |           |                   |    |            |    |                   |     |            |     |  |
| ERU-5   | Berner      |         |                 |                |           |                  |                |           |           |                   |    |            |    |                   |     |            |     |  |

| Cooling Conditions |    |               |     |          |             | Heating Conditions |     |           |    | Volts-Phase-Hertz | FLA | MCA | Remarks |
|--------------------|----|---------------|-----|----------|-------------|--------------------|-----|-----------|----|-------------------|-----|-----|---------|
| LAT                |    | Chilled Water |     | DX Suct. | Max Cooling | LAT                |     | Hot Water |    |                   |     |     |         |
| db                 | wb | EWT           | GPM |          |             | db                 | EWT | GPM       | kw |                   |     |     |         |
|                    |    |               |     |          |             |                    |     |           |    |                   |     |     |         |
|                    |    |               |     |          |             |                    |     |           |    |                   |     |     |         |
|                    |    |               |     |          |             |                    |     |           |    |                   |     |     |         |
|                    |    |               |     |          |             |                    |     |           |    |                   |     |     |         |

**The above schedule is available in Excel and can be pasted into autocad with the following steps: Contact Berner for a copy. 1-800-479-0988**

- 1) Copy the cells that you would like to paste into AutoCAD
- 2) Open AutoCAD
- 3) Under the Edit drop down menu select paste special
- 4) Select paste and then select as: Autocad Entities and hit Ok
- 5) Position where you want to put it on your drawing
- 6) If you need to make changes or edit the schedule you can use you edit command in AutoCAD









## Berner's Electrical Calculations - SRC

| <i>Calculation Chart</i>                 |                       |                 |                 |
|--|-----------------------|-----------------|-----------------|
| <i>Electrical Parts</i>                  | <i>Input Amp Draw</i> |                 |                 |
|  | <i>208 Volt</i>       | <i>240 Volt</i> | <i>480 Volt</i> |
| Biggest Fan HP Motor                     |                       |                 |                 |
| Smallest Fan HP Motor                    |                       |                 |                 |
| Heat Wheel Motor                         |                       |                 |                 |
| Enthalpy Wheel Rotation Detection        |                       |                 |                 |
| Damper Motor - total                     |                       |                 |                 |
| Radiant Defrost Heater - total           |                       |                 |                 |
| Temperature Sensors - total              |                       |                 |                 |
| Lights and Receptical                    |                       |                 |                 |
| Variable Frequency Drive per Fan - total |                       |                 |                 |
| Misc. Panel Requirments                  | 3.6                   | 3.2             | 1.6             |

| <i>Electrical Load Results</i> | <i>208 Volt</i> | <i>240 Volt</i> | <i>480 Volt</i> |
|--------------------------------|-----------------|-----------------|-----------------|
| Full Load Amps - FLA           |                 |                 |                 |
| Minimum Circuit Ampacity - MCA |                 |                 |                 |

**Direction:** Insert the amps for each component (*In the area marked Calculation Chart*) that you plan on using from the chart on the right labeled *Electrical Component Amps*. You can find the Fan and Heat Wheel Motor HP on the data sheets under each model *Selection Tab* and *cfm selection*. First input the amps for the largest fan motor (supply or exhaust). Second input the smallest motor amps (if the fan motors are the same then input the amps in both). Third input the designated Heat Wheel Motor amps. Fourth input only the Accessories Amp Draws that you wish to use.

**To calculate FLA: Add each column per Desired Voltage**

**To calculate MCA: (Largest Fan Motor x 1.25) Plus FLA**

**Caution: FLA & MCA may vary +/- 5 amps depending on Manufactures of Parts**

| <i>Electrical Component Amp Draw</i> |                 |                 |                 |
|--------------------------------------|-----------------|-----------------|-----------------|
| <i>Fan Motors</i>                    | <i>208 Volt</i> | <i>240 Volt</i> | <i>480 Volt</i> |
| 3/4 HP Motor                         | 3.50            | 3.20            | 1.60            |
| 1 HP Motor                           | 3.10            | 3.00            | 1.50            |
| 1 1/2 HP Motor                       | 4.50            | 4.40            | 2.20            |
| 2 HP Motor                           | 6.00            | 5.90            | 3.00            |
| 3 HP Motor                           | 8.60            | 8.40            | 4.20            |
| 5 HP Motor                           | 14.00           | 12.70           | 6.40            |
| 7 1/2 HP Motor                       | 21.00           | 19.00           | 9.50            |
| 10 HP Motor                          | 27.30           | 24.70           | 12.30           |
| 15 HP Motor                          | 41.00           | 38.00           | 19.00           |
| 20 HP Motor                          | 54.00           | 50.00           | 24.90           |
| 25 HP Motor                          | 66.00           | 60.00           | 30.00           |
| 30 HP Motor                          | 78.00           | 71.00           | 35.00           |

| <i>Heat Wheel Motor</i>        | <i>208 Volt</i> | <i>240 Volt</i> | <i>480 Volt</i> |
|--------------------------------|-----------------|-----------------|-----------------|
| 1/4 HP Motor 3820 - 5855 units | 1.00            | 1.00            | 0.50            |
| 1/3 HP Motor 6875 - 7812 units | 1.20            | 1.20            | 0.60            |
| 1/2 HP Motor 8815 - 9620 units | 1.80            | 1.80            | 0.90            |

| <i>Accessories Amp Draw</i>             | <i>208 Volt</i> | <i>240 Volt</i> | <i>480 Volt</i> |
|---|-----------------|-----------------|-----------------|
| Enthalpy Wheel Rotation Detection       | 0.20            | 0.20            | 0.10            |
| Damper Motor - each                     | 0.75            | 0.75            | 0.50            |
| Radiant Defrost Heater Pkg. - each      | 4.57            | 3.95            | 1.97            |
| Temperature Sensor - each               | 0.50            | 0.50            | 0.25            |
| Lights and Receptical                   | 12.00           | 12.00           | 6.00            |
| Variable Frequency Drive per Fan - each |                 |                 |                 |